

















**LEGENDA:**

-  Kamera u Ex zaštiti
-  Monitor u Ex zaštiti - Zona E1
-  Zglobni nosač za kameru
-  Razvodni orman video nadzora RO-V
-  Razvodni orman strujni postojeći RO
-  Razvodna kutija u Ex zaštiti - RK
-  Razvodna kutija u IP66 zaštiti - RKII
-  Završna optička kutija ZOK
-  Kabl koaksijalni RG-59 HF + Kabl N2XH 3x1,5mm<sup>2</sup> + Kabl N2XH-J 6mm<sup>2</sup>
-  Kabl F/FTP cat.6a HF + Kabl N2XH 3x1,5mm<sup>2</sup> + Kabl N2XH-J 6mm<sup>2</sup>
-  Kabal N2XH 3x1,5mm<sup>2</sup>
-  Kabal N2XH-J 16mm<sup>2</sup>
-  Spust uzemljenja - postojeći
-  Broj kablova
-  Prekidač energetskog napajanja
-  Regal PNK 100

**Napomena:** Kablovi N2XH 3x1,5mm<sup>2</sup> i N2XH-J 6mm<sup>2</sup> se unutar objekta polažu nazidno obujmicama ili u PNK regalu, a kablovi RG59 i F/FTP cat 6a u cevi Ø20mm ili PNK regalu, a izvan objekta postojećim ili novim PNK regalima

	DOO "ELSAT"		Vrsta tehničke dokumentacije
	Gvozdena Paunovića br.6		PIO
32000 Čačak, 032/350-222, www.elsat.rs		PEČAT I POTPIS	INVESTITOR:
ODGOVORNI PROJEKTANT: Nemanja Savić dipl.el.ing. br. licence: 353 O432 15			"UNDP", Bulevar Zorana Đinđića 64, Beograd
PROJEKTANT: Aleksandar Stefanović dipl.el.ing. br. licence: 353 O061 15			OBJEKAT: Tehnički remontni zavod Kragujevac
CRTAO: Aleksandar Stefanović dipl.el.ing. br. licence: 353 O061 15			PROJEKTAT: Projekat izvedenog objekta sistema video nadzora
NAZIV CRTEŽA: Objekat 43			DEO PROJEKTA: 5 - TELEKOMUNIKACIONE I SIGNALNE INSTALACIJE
RAZMERA:	DATUM: Novembar, 2016.god.	PROJEKAT BROJ: 6982/1	LIST BROJ: 6